

To:

TuffX Processed Glass Ltd

Nexus House, Randles Rd

Knowsley Business Park

Knowsley

Liverpool L34 9HX

Mr. John Hayes



Working in co-operation with
TÜV Rheinland Nederland B.V.

Statement Ref ERCT 0431/1 & ERCT0431

This is to declare that the product 'Glow Glass' Thermal walk on roof light manufactured by TuffX Processed Glass Ltd met the following indicative tests;

Indicative test performed to the same requirements as PAS24-2016 C.4.4.3 Mechanical Infill test
(Test date 08/02/2019)- 2kN loads applied at the corners of the glazing aperture and no entry was gained. The test was repeated with 4kN loads and again there was no breakage or deformation of the product.

Indicative test performed to the same requirements as BS6375-1 Weather On-going test
(Test date 13/02/2019)- The sample provided (1000mm x 1000mm) appears to **meet** the manufacturer's chosen requirements from the European standard EN 14351-1 [1], **BS6375-1 Weather**, the sample appears to have achieved the following results;

- Air Permeability EN12207 – sample appears to have achieved Class 4, 600Pa.
- Water Tightness EN12208– sample appears to have achieved Class A9, 600Pa.

Tests were performed on manufacturer's samples and executed by personel of ERC Testing Ltd, Unit A8(3), Pennington Court, Walter Leigh Way, Moss Industrial Estate, Leigh WN7 3PT, United Kingdom.

ERC Testing Ltd.

Onsite contacts: Mike Hackett & Pete Fradley

mike.hackett@erc-testing.com & pete.fradley@erc-testing.com


Unit A8(3), Pennington Court, Moss Industrial Estate, Leigh Lancashire WN7 3PT

Tel: 01942 603927

Reg. Office: 78 Borough Road, Altrincham, Cheshire WA15 9EJ


Director: W F Keating Mobile: 07980 863175 Email: bill.keating@er-certification.com

Company Registration No. 9819101



Thermal Walk on Roof Light


33mm Toughened Laminated Glass
Argon Gas Filled Cavity with Warm Edge Spacer
6mm Toughened Low E Glass



ERC Testing Ltd.

Onsite contacts: Mike Hackett & Pete Fradley
mike.hackett@erc-testing.com & pete.fradley@erc-testing.com
 Unit A8(3), Pennington Court, Moss Industrial Estate, Leigh Lancashire WN7 3PT
 Tel: 01942 603927
 Reg. Office: 78 Borough Road, Altrincham, Cheshire WA15 9EJ
 Director: W F Keating Mobile: 07980 863175 Email: bill.keating@er-certification.com
 Company Registration No. 9819101

Air Permeability Average:



ERC Testing Ltd.

Onsite contacts: Mike Hackett & Pete Fradley

mike.hackett@erc-testing.com & pete.fradley@erc-testing.com

Unit A8(3), Pennington Court, Moss Industrial Estate, Leigh Lancashire WN7 3PT

Tel: 01942 603927

Reg. Office: 78 Borough Road, Altrincham, Cheshire WA15 9EJ

Director: W F Keating Mobile: 07980 863175 Email: bill.keating@er-certification.com

Company Registration No. 9819101